

Archived: Tuesday, August 09, 2016 2:48:20 PM

From: Jason P Ericson (Services - 6)

Sent: Monday, August 08, 2016 11:43:14 AM

To: Glassman, Joseph (DEQ)

Cc: Chapman, Randy (DEQ); John Black (VirginiaPower - 1); Jason E Williams (Services - 6); Amanda B Tornabene (Services - 6); John D Dicarlo (VirginiaPower - 1); Brett W Paulin (Services - 6); Paula A Hamel (Services - 6); Erica L Stratton (Services - 6)

Subject: Crystal Substation and Roaches Run Weekly Update: August 8, 2016

Importance: Normal

Mr. Glassman,

As requested in your February 23, 2016 letter, below is the weekly update for activities at the Crystal Substation and at Roaches Run/Gravelly Point. The absorbent and hard booms from the Roaches Run outfall area have been removed. Our inspections continue to find no remaining signs of sheen or oil.

If you have any questions please contact John Black or me.

**Crystal Substation Daily
Inspection Notes: August 8, 2016**

Tuesday 10:45 am Aug 2 (low tide) – Storm water drop inlet outside the Station showed no signs of oil or sheen. Roaches Run outfall showed no signs of oil. Gravelly Point boat launch area showed no amounts of sheen. Roaches Run parking area showed no signs of sheen.

Thank you,
Jason

Jason P. Ericson, PG
Dominion Resources Services, Inc.
Environmental Policy
5000 Dominion Blvd
Glen Allen, VA 23060
Phone: (804) 273-3012
Mobile: (804) 317-9464
Fax: (804) 273-2964

CONFIDENTIALITY NOTICE: This electronic message contains information which may be legally confidential and or privileged and does not in any case represent a firm ENERGY COMMODITY bid or offer relating thereto which binds the sender without an additional express written confirmation to that effect. The information is intended solely for the individual or entity named above and access by anyone else is unauthorized. If you are not the intended recipient, any disclosure, copying, distribution, or use of the contents of this information is prohibited and may be unlawful. If you have received this electronic transmission in error, please reply immediately to the sender that you have received the message in error, and delete it. Thank you.