

UNIT PROCESS: Septic Tank/Dosing Siphon/Sand Filter

- 1. Grease trap preceding septic tank: Yes No NA
- 2. When was septic tank last pumped?
- 3. Dosing siphon operational (doesn't trickle): Yes No NA
- 4. Condition of dosing siphon: Good Fair Poor*
- 5. Number of sand filters:
- 6. Condition of distribution system including seals: Good Fair Poor*
- 7. Following problems evident:
 - a. grass on filter Yes* No
 - b. ponding Yes* No
 - c. uneven sand Yes* No
 - d. places of black or septic sand Yes* No
 - e. uneven distribution of influent Yes* No
 - f. solids on surface Yes* No
- 8. Wasted sand disposed of properly? Yes No*

Comments: