

**BY U.S. MAIL**  
**RETURN RECEIPT REQUESTED**

September 8, 2016

Ms. Beverley Carver  
Department of Environmental Quality  
Valley Regional Office  
4411 Early Road  
Harrisonburg, VA 22801

**RE: Dominion Bremo Power Station VA0004138**  
**Weekly Discharge Monitoring and Site Activity Report**


Ms. Carver:

Dominion is submitting this letter in accordance with Part I.A.9.h. of the subject permit. Information related to discharge sampling activities for Outfall 504 conducted during the week of August 28 – September 3, 2016 is included on the enclosed Weekly Compliance Sampling Summary. There was no discharge from Outfalls 501, 502, 503, or 505 during this period. In addition to the Weekly Compliance Sampling Summary, this submission includes a status report, summarizing the activities related to the CCR Surface Impoundment Closure Project, and the Monthly Enhanced Metals Treatment Log.

If you have any questions or need additional information, please contact Taylor Engen at 434-842-4104.

*I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.*

Sincerely,



William Reed  
Director, Power Generation Station II

**WEEKLY COMPLIANCE SAMPLING SUMMARY**

Facility Name: Breomo Power Station

Sample Week: 8/28/16 - 9/3/16

Permit Number: VA0004138  
 Outfall Number: 504

Report Due Date: September 9, 2016

Parameter	Units	Sample Date			Permit QL	Daily Maximum Limitation	Analytical Report Date			Result
		8/29/2016	8/31/2016	9/1/2016			8/29/2016	8/31/2016	9/7/2016	
Estimated Flow	MGD	-	-	-	-	-	0.579	0.643	0.000	ND
pH	S.U.	NA	9.0	7.9	9.0	7.8	< QL	< QL	ND	ND
Total Suspended Solids	mg/L	1.0	100.0	< QL	1.0	< QL	< QL	< QL	ND	ND
Oil & Grease	mg/L	5.0	20.0	< QL	5.0	< QL	< QL	< QL	ND	ND
Antimony, Total Recoverable	ug/L	5.0	2,100	< QL	5.0	< QL	< QL	< QL	ND	ND
Arsenic, Total Recoverable	ug/L	5.0	530	62.3	5.0	65.0	< QL	< QL	ND	ND
Cadmium, Total Recoverable	ug/L	1.0	3.2	< QL	1.0	< QL	< QL	< QL	ND	ND
Chromium III, Total Recoverable	ug/L	5.0	220	< QL	5.0	< QL	< QL	< QL	ND	ND
Chromium VI, Total Recoverable	ug/L	5.0	34	< QL	5.0	< QL	< QL	< QL	ND	ND
Copper, Total Recoverable	ug/L	5.0	23	< QL	5.0	< QL	< QL	< QL	ND	ND
Lead, Total Recoverable	ug/L	5.0	35	< QL	5.0	< QL	< QL	< QL	ND	ND
Mercury, Total Recoverable	ug/L	0.1	2.8	< QL	0.1	< QL	< QL	< QL	ND	ND
Nickel, Total Recoverable	ug/L	5.0	57	< QL	5.0	< QL	< QL	< QL	ND	ND
Selenium, Total Recoverable	ug/L	5.0	18	< QL	5.0	< QL	< QL	< QL	ND	ND
Silver, Total Recoverable	ug/L	0.4	5.0	< QL	0.4	< QL	< QL	< QL	ND	ND
Thallium, Total Recoverable	ug/L	1.0	1.4	< QL	1.0	< QL	< QL	< QL	ND	ND
Zinc, Total Recoverable	ug/L	25	210	< QL	25	< QL	< QL	< QL	ND	ND
Chloride	mg/L	10	820	49.3	10	37.3	< QL	< QL	ND	ND
Ammonia-N	mg/L	0.20	14	< QL	0.20	< QL	< QL	< QL	ND	ND
Hardness	mg/L	NA	NL	157	NA	146	< QL	< QL	ND	ND

**Notes:**

pH values must remain between a minimum of 6 S.U. and a maximum of 9 S.U. pH values are measured in the field.  
 Analytical results below the permit Quantification Level (QL) are to be reported as "<QL," as required in Section I.C.2 of the Permit  
 QL = Quantification Level  
 NA = Not Applicable  
 NL = No Limitation, monitoring required  
 ND = No Discharge during monitoring period

**Dominion – Bremo Power Station**

**CCR Impoundment Closure Project**

**Weekly Status Report**

**Activities for the Week Ending: 9/3/2016**

- 1.22 MG of Centralized Source Water Treatment System (CSWTS)-treated water was discharged via Outfall 002.
- 3.15 MG water from the Stormwater Management Pond was filtered and discharged via Outfall 002.

**Ongoing Activities**

- Transport of material from the West Pond to the North Pond.
- Installation of wellpoints and headers in the North Pond.
- Pumping of water (filtered) from the Stormwater Management Pond to Outfall 002.
- Discharge of CSWTS-treated water to Outfall 002.
- Confirmation of no discharge at Outfall 004.

**Look Ahead**

- Obtain agreement on proposed compliance sampling strategies during low discharge conditions per Dominion July 28, 2016 email submittal to DEQ.

<b>Bremo Power Station Enhanced Metals Treatment Log - August 2016</b>			
<b>Date</b>	<b>ON (Time)</b>	<b>OFF (Time)</b>	<b>Reason(s) for Enhanced Treatment Activation</b>
1-Aug	X (23:05)		Arsenic trigger value reached.
2-Aug		X (11:36)	
3-Aug	X (06:20)	X (15:10)	Arsenic trigger value reached.
4-Aug		X	
5-Aug		X	
6-Aug	X (10:45)		Thallium trigger value reached.
7-Aug		X (04:50)	
8-Aug		X	
9-Aug		X	
10-Aug		X	
11-Aug		X	
12-Aug		X	
13-Aug		X	
14-Aug		X	
15-Aug		X	
16-Aug		X	
17-Aug		X	
18-Aug		X	
19-Aug		X	
20-Aug		X	
21-Aug		X	
22-Aug		X	
23-Aug		X	
24-Aug		X	
25-Aug	X (14:10)	X (22:13)	Arsenic trigger value reached.
26-Aug		X	
27-Aug		X	
28-Aug		X	
29-Aug		X	
30-Aug		X	
31-Aug		X	

Note: All On/Off times are approximate