

Central Office, P. O. Box 1105, Richmond, Virginia 23218

The purpose of this notice is to announce that the Virginia Dept. of Environmental Quality received a Joint Permit Application for a surface water withdrawal for public water supply from the Potomac River in Loudoun County, Virginia and Montgomery County, MD. Applicant: Loudoun County Sanitation Authority (d.b.a. Loudoun Water), 44865 Loudoun Water Way, Ashburn, VA 20146; Virginia Water Protection Joint Permit Application No. 10-2020. The construction and operation of a new 40 million gallons per day (mgd) public drinking water supply intake; pump station; 20-mgd water treatment plant; 1 billion gallon storage capacity in Luck Stone Quarry A; raw water transmission lines from river to Quarry A and from Quarry A to treatment plant; and finished water transmission line from treatment plant to interconnection with existing water supply distribution system. The DEQ contact is: Brenda Winn, Phone (804) 698-4516; Email: brenda.winn@deq.virginia.gov; Fax (804) 698-4032.